



These Signage are normally used at the Doorways or Entrances to Rooms having Clean Agent Fire Extinguishing Systems.

The 'EVACUATE AREA IMMEDIATELY' signage are mounted within the protected area, normally at the exit doorways, notifying personnel to evacuate once the fire alarm is activated.

The 'GAS DISCHARGED' signage are mounted at the entrances to protected areas, to caution personnel against entering the protected rooms during fire alarm or gas discharged.



Model	Standard (Indoor)		Weatherproof (Outdoor)	
	EA-V4	GD-V4	EA-V4-W	GD-V4-W
Wordings on Perspex	<b>EVACUATE AREA IMMEDIATELY</b>	<b>GAS DISCHARGED</b>	<b>EVACUATE AREA IMMEDIATELY</b>	<b>GAS DISCHARGED</b>
Material / Finishing	Galvanized Steel / Powder Coated, Beige with Texture Finishing			
Signage Material	Red Perspex, with wordings on the inside			
Light Source	High Luminance LED Lights. Field selectable to be 'Steady' or 'Flashing'			
Rated Voltage / Current	24 VDC / 60 mA			
Approximate Weight	1.0 kg		2.7 kg	
Ingress Protection	IP30		IP54	



- Cabinet made of Corrosion Resistant Galvanized Steel
- Low Current Consumption using High Luminance LED
- Field Selectable Option for 'Steady' or 'Flashing' Lights
- Low Cost, Durable & Maintenance-Free
- Weatherproof Cabinet is available for outdoor used
- Customization of Wordings & Cabinet colour are available on special request.

### Typical Internal View of the Cabinet

SMT mounted high luminance LED which are evenly spaced within the Cabinet, providing consistence lightings on the display surface when activated.

### Multron Systems Pte Ltd

217 Kallang Bahru, Multron Building, Singapore 339 347

6395 6868  
6395 6869

info@multron.com  
www.multron.com

